

SAFE DRINKING WATER AND SANITARY CONDITION CERIFICATE


Ref No. 28

Dated: 04.05.2023

It is certified that an inspection team headed by Mr. BHUBANI CHANDRA HALBA, SANITARY INSPECTOR from Health Office, Jeypore Municipality.

Inspected the Novel Sidharth English Medium School on 04-05-2023 (date of inspection) and found that the Novel Sidharth English Medium School (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the central/state/U.T. Govt.


The above is valid for a period of 2 years


4/5/2023
Sanitary Inspector
Jeypore Municipality

To

Novel Sidharth English Medium School

Jeypore


PRINCIPAL
Novel Sidharth English
Medium School, Jeypore
Dist:Koraput, Odisha-764001


MANAGER
Novel Sidharth English
Medium School, Jeypore
Dist:Koraput, Odisha-764001

OFFICE OF THE JUNIOR ENGINEER: P.H. SECTION: JEYPORE

Letter No.

156

Dt. 06.07.23

To

*The Principal
Novel Sidharth English Medium School*

Sub: Regarding Safe Drinking Water Certificate

Ref: Your Lr. No- 34NSEMS/22/23 Dt.27.03.2023.

Sir,

With reference to the above subject, I am to intimate you that the water which is supply to the said premises through piped water supply of P.H.E.O. is safe for drinking purpose.

This is for your information

Yours faithfully


Junior Engineer


P.H. Section, jeypore

Memo.No.

Dated..

*Copy Submitted to the Executive Engineer, P.H. Sub-Division, Jeypore
Vide ^{you} Memo No- 428 Dt- 27.3.23 for favour of kind information and necessary action.*

*Junior Engineer
P.H. Section, Jeypore*


PRINCIPAL
Novel Sidharth English
Medium School, Jeypore
Dist:Koraput, Odisha-764001


MANAGER
Novel Sidharth English
Medium School, Jeypore
Dist:Koraput, Odisha-764001

08.04.2023


P.H. LABROTARY, JERPORE
Analytical report along with drinking water specification,
Bureau of India Standard (IS 10500:2012)

SAMPLE SOURCE: NOVEL SIDHART ENGLISH MEDIUM SCHOOL

DATE OF RECEIVING SAMPLE: 07.04.2023

Sl. No	Parameter	Results	Acceptable Limit	Cause Of Rejection
1	Color	Color Less	-	-
2	Odour	Odour Less	-	-
3	Turbidity in NTU	0.2	1	5
4	PH	7.1	6.5 to 8.5	Beyond acceptable limit
5	Free Chlorine, mg/L	0.3	0.2	1
6	Bacteriological Quality	Found Safe	Shall not be Detecable in any 100ml sample	No relaxation

We found that NOVEL SIDHART ENGLISH MEDIUM SCHOOL has safe drinking water facility for the student and members of Staff of school.


PRINCIPAL
Novel Sidharth English
Medium School, Jeypore
Dist:Koraput, Odisha-764001


MANAGER
Novel Sidharth English
Medium School, Jeypore
Dist:Koraput, Odisha-764001


Lab Assistant
P.H.D., Jeypore